



MISSOURI DEPARTMENT OF TRANSPORTATION

3602 North Belt Highway • St. Joseph, Missouri 64506-1399 • (816) 387-2430

ADDENDUM 002

Request for Quotation: D1-08-006

The due date for receipt of quotations remains unchanged by this Addendum. Accordingly, the following changes, questions and answers are believed to be of general interest to all potential Offerors. The original solicitation is hereby changed to the extent stated in the department's response to each question on the attached pages of this amendment 001. All other terms and conditions remain unchanged and in full force. Please sign and return with your quotation.

Name and Title of Signer (Print or type)	Name and Title of Department Authority Brenda Christie Procurement Agent
Contractor/Offeror Signature	Department of Transportation <i>Brenda Christie</i>
(Signature of person authorized to sign)	(Authorizing Signature)
Date Signed:	Date Signed: <i>August 16, 2007</i>

Questions and Answers:

1. Is the contractors responsible for pulling wire down to light fixtures?
Yes
2. Does contractors need to get a city permit?
No
3. Does the contractors have to install all switches, receptacles, plates, etc.
Yes

Clarifications

1. All light switch boxes and receptacles are in place already.
2. All data and phone lines are pulled by MoDOT personnel.
3. Need to have a receptacle recessed for AC 120V 20 amp in radio room on west wall.
4. All computer boxes are marked with red paint.
5. Main feed breaker panel has snap in breakers (per Jamie).
6. There will need to be three additional 2 x 2 fixtures installed by MoDOT and contractor required to run wire to them.
7. All emergency lighting can be dedicated to one electrical circuit (per Jamie).